

# DATA SHEET

## Three Phase Induction Motor - Squirrel Cage



Customer :

Product line : W21 Explosion Proof NEMA Premium  
Efficiency Three-Phase

Product code : 14443258

Catalog # : 04036XT3H324TS

Frame	: 324TS	Locked rotor time	: 54s (cold) 30s (hot)
Output	: 40 HP (30 kW)	Temperature rise	: 80 K
Poles	: 2	Duty cycle	: Cont.(S1)
Frequency	: 60 Hz	Ambient temperature	: -20°C to +40°C
Rated voltage	: 575 V	Altitude	: 1000 m.a.s.l.
Rated current	: 37.0 A	Protection degree	: IP55
L. R. Amperes	: 244 A	Cooling method	: IC411 - TEFC
LRC	: 6.6x(Code G)	Mounting	: F-1
No load current	: 10.4 A	Rotation <sup>1</sup>	: Both (CW and CCW)
Rated speed	: 3560 rpm	Noise level <sup>2</sup>	: 81.0 dB(A)
Slip	: 1.11 %	Starting method	: Direct On Line
Rated torque	: 59.0 ft.lb	Approx. weight <sup>3</sup>	: 620 lb
Locked rotor torque	: 250 %		
Breakdown torque	: 260 %		
Insulation class	: F		
Service factor	: 1.15		
Moment of inertia (J)	: 4.90 sq.ft.lb		
Design	: B		

Output	25%	50%	75%	100%
--------	-----	-----	-----	------

Efficiency (%)	92.2	92.4	93.6	93.6
Power Factor	0.55	0.79	0.85	0.87

Foundation loads

Max. traction : 279 lb  
Max. compression : 898 lb

	Drive end	Non drive end
Bearing type	: 6312 C3	6212 C3
Sealing	: Oil Seal	Lip Seal
Lubrication interval	: 9829 h	12143 h
Lubricant amount	: 21 g	13 g
Lubricant type	Mobil Polyrex EM	

Notes:

This revision replaces and cancel the previous one, which must be eliminated.

- (1) Looking the motor from the shaft end.
- (2) Measured at 1m and with tolerance of +3dB(A).
- (3) Approximate weight subject to changes after manufacturing process.
- (4) At 100% of full load.

These are average values based on tests with sinusoidal power supply, subject to the tolerances stipulated in NEMA MG-1.

Rev.	Changes Summary	Performed	Checked	Date
Performed by		Page Revision 1 / 2		
Checked by				
Date	28/03/2024			

DATA SHEET

Three Phase Induction Motor - Squirrel Cage



Customer :

Thermal protection

ID	Application	Type	Quantity	Sensing Temperature
1	Winding	Thermostat - 2 wires	1 x Phase	155 °C

Rev.	Changes Summary		Performed	Checked	Date
Performed by				Page	Revision
Checked by					
Date	28/03/2024			2 / 2	