DATA SHEET

Three Phase Induction Motor - Squirrel Cage



: 23s (cold) 13s (hot)

: 80 K

: IP24

: F-1

: CW : 82.0 dB(A)

: 6225 lb

: Cont.(S1)

: -20°C to +40°C

: 1000 m.a.s.l.

: Direct On Line

Customer

Product line : W60 Standard Efficiency Three-Phase Product code: 16166620

Locked rotor time

Temperature rise

Protection degree

Ambient temperature

Duty cycle

Altitude

Mounting

Rotation¹

Noise level²

Starting method

Approx. weight3

Frame : 5810/11

Output : 1350 HP (1000 kW)

Poles : 4 Frequency : 60 Hz Rated voltage : 690 V : 1008 A Rated current : 6549 A L. R. Amperes LRC : 6.5x(Code G)

No load current : 331 A Rated speed : 1780 rpm Slip : 1.11 % Rated torque : 3980 ft.lb Locked rotor torque : 120 % Breakdown torque : 250 %

Insulation class : F : 1.00 Service factor

: 175 sq.ft.lb Moment of inertia (J)

Output 25% 50% 75% 100% Foundation loads Efficiency (%) 96.9 96.8 96.8 96.6 Max. traction 0.82 Power Factor 0.49 0.74 0.86 Max. compression

Drive end Bearing type 6224 C3 Without Bearing Seal Sealing

Lubrication interval 20000 h 43 g Lubricant amount Lubricant type

Non drive end 6218 C3 Without Bearing Seal

20000 h 24 g

Mobil Polyrex EM

Notes:

This revision replaces and cancel the previous one, which must be eliminated.

- (1) Looking the motor from the shaft end.
- (2) Measured at 1m and with tolerance of +3dB(A).
- (3) Approximate weight subject to changes after manufacturing process.

(4) At 100% of full load.

These are average values based on tests with sinusoidal power supply, subject to the tolerances stipulated in NEMA MG-1.

Rev.	Changes Summary		Performed	Checked	Date
Performed by					
Checked by				Page	Revision
Date	27/03/2024			1/2	

DATA SHEET

Three Phase Induction Motor - Squirrel Cage



Customer	

Thermal	protection
---------	------------

ID	Application	Туре	Quantity	Sensing Temperature
1	Winding	PT100 - 3 wires	2 x Phase	-
2	DE bearing	PT100 - 3 wires	1 x Bearing	-
3	NDE bearing	PT100 - 3 wires	1 x Bearing	-

Space heater information

Voltage: 110-127/200-240 V

Rev.	Changes Summary Performed		Performed	Checked	Date
Performed by					
Checked by				Page	Revision
Date	27/03/2024			2/2	