DATA SHEET

Three Phase Induction Motor - Squirrel Cage



: 27s (cold) 15s (hot)

Customer :

Product line : W60 Standard Efficiency Three-Phase Product code : 16166512

Frame : 5010/11 Locked rotor time

Output : 700 HP (515 kW) Temperature rise : 80 K Poles : 2 Duty cycle : Cont.(S1) Frequency : 60 Hz Ambient temperature : -20°C to +40°C Rated voltage : 460 V Altitude : 1000 m.a.s.l. Protection degree : IP24 Rated current : 755 A

: F-1 Mounting L. R. Amperes : 4528 A LRC : 6.0x(Code F) Rotation¹ : CW No load current : 115 A Noise level² : 85.0 dB(A) Rated speed : 3560 rpm Starting method : Direct On Line : 4322 lb

Slip : 1.11 % Approx. weight³
Rated torque : 1030 ft.lb
Locked rotor torque : 60 %
Breakdown torque : 200 %
Insulation class : F
Service factor : 1.00

Output 25% 50% 75% 100% Foundation loads Efficiency (%) 95.0 95.2 96.2 96.2 Max. traction 0.89 Power Factor 0.68 0.84 88.0 Max. compression

: 78.3 sq.ft.lb

Drive endNon drive endBearing type: 6218 C46218 C4Sealing: Without Bearing SealWithout Bearing SealLubrication interval: 12045 h12045 h

Lubricant amount : 24 g 24 g

Lubricant type : Mobil Polyrex EM

Notes:

Moment of inertia (J)

This revision replaces and cancel the previous one, which must be eliminated.

- (1) Looking the motor from the shaft end.
- (2) Measured at 1m and with tolerance of +3dB(A).
- (3) Approximate weight subject to changes after manufacturing process.

(4) At 100% of full load.

These are average values based on tests with sinusoidal power supply, subject to the tolerances stipulated in NEMA MG-1.

Rev.	Changes Summary		Performed	Checked	Date
Performed by					
Checked by				Page	Revision
Date	27/03/2024			1/2	

DATA SHEET

Three Phase Induction Motor - Squirrel Cage



Customer	

Thermal	protection
---------	------------

ID	Application	Туре	Quantity	Sensing Temperature
1	Winding	PT100 - 3 wires	2 x Phase	-
2	DE bearing	PT100 - 3 wires	1 x Bearing	-
3	NDE bearing	PT100 - 3 wires	1 x Bearing	-

Space heater information

Voltage: 110-127/200-240 V

Rev.	Changes Summary Performed		Performed	Checked	Date
Performed by					
Checked by				Page	Revision
Date	27/03/2024			2/2	