



These devices shall be mounted on enclosures having adequate strength and thickness and with adequate spacing provided. Seal rating is based on mounting to a surface that is clean, flat and smooth.

| PIC RATINGS/SPECIFICATIONS | |
|----------------------------|-----------------------------|
| VOLTS: | 125V |
| AMPS: | 15A |
| SCCR: | 0.2kA |
| NEMA/UL EN 60529: | 4, 12 IP65 |
| PANEL THICKNESS: | 5.0mm max |
| MOUNTING SCREW TORQUE: | 0.8N-m |
| TERMINAL BLOCK TORQUE: | 0.5N-m |
| INCOMING POWER WIRE SIZE: | 0.25 - 2.5 sq mm / 24-12AWG |
| WIRE STRIP LENGTH: | 7 - 8 mm |

| HOUSING MATERIALS | |
|-------------------|--------------------------------|
| BODY: | EPOXY COATED DIE CAST ALUMINUM |
| GASKET: | THERMOPLASTIC ELASTOMER |
| HANDLE: | POLYAMIDE |
| LEVERS: | STAINLESS STEEL |

MOUNTING KIT ORDERED SEPARATELY CONTAINS M4x0.7 SS SCREW, NYLON WASHER, SPLIT LOCKWASHER AND M4 NUT
P/N: D-PIC-MT



UNLESS OTHERWISE SPECIFIED:
 DIMENSIONS ARE IN INCHES AND [MM]

| | |
|-------------|------------|
| DRAWN BY: | DCG |
| DRAWN DATE: | 11/21/2018 |
| CHECKED BY: | GO |
| CHECK DATE: | 11/26/2018 |

MENCOM CORPORATION
 TITLE:
GFI; RJ45; 15A; 32

| STANDARD CONFIGURATIONS UNLESS OTHERWISE NOTED | | |
|------------------------------------------------|-------------|-------------|
| CONN. TYPE | EXTERIOR | INTERIOR |
| RJ45 | CAT. 6 JACK | CAT. 6 JACK |

PROPRIETARY AND CONFIDENTIAL
 THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF MENCOM CORPORATION. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF MENCOM CORPORATION IS PROHIBITED.

| | |
|----------------------|--|
| MATERIAL | |
| FINISH | |
| DO NOT SCALE DRAWING | |

COMMENTS:

| | | |
|------------|-----------------------|--------------|
| SIZE | DWG. NO. | REV |
| B | GF-RJ45-15R-32 | D |
| SCALE: 2:3 | WEIGHT: | SHEET 1 OF 1 |